



**FRANCHISE UTILITIES CONSTRUCTION NOTES:**

- ① INSTALL 4-3" SCHEDULE 40 ELECTRICALLY RATED PVC CONDUIT, 36" MINIMUM BELOW FINISH GRADE. 36" FIBERGLASS SWEEPS REQUIRED ON ALL RUNS. CONTACT CENTRAL LINCOLN PUD FOR TRENCH INSPECTION PRIOR TO BACKFILL.
- ② SEE ELECTRICAL OR POWER PLAN DRAWINGS FOR TRANSFORMER DETAILS.

FOR REFERENCE ONLY. VERIFY ACTUAL CONDUIT PLAN WITH FRANCHISE COMPANY.

**PRELIMINARY**  
NOT FOR CONSTRUCTION

**Devco**  
engineering inc.  
640 787-8991  
245 NE CONNER, P.O. BOX 1231  
CORVALLIS, OR 97339  
WWW.DEVCOENGINEERING.COM  
© COPYRIGHT 2023  
DEVCO ENGINEERING, INC.  
ALL RIGHTS RESERVED.

**SHS COASTAL STARS**  
SAMARITAN HEALTH SERVICES  
5840 NW Biggs St, Newport, OR 97365



ISSUE DATE: 05.30.23  
REVISIONS:  
△ ADDENDUM 02 08/07/23  
△ ASI 01 09/08/23

FRANCHISE UTILITIES  
PLAN



PERMIT

FILE: I:\DL\30 - Projects\22435 (Production Drawings)\P\22435\DWG [17/18/2023 4:50 PM] - Koree